

**ENERGY AUDIT REPORT  
OF  
SHREE SANTKRUPA COLLEGE OF  
PHARMACY,  
Ghogaon (Shivajinagar)**



**Year: 2020-21**

Prepared by:

**Enrich Consultants**

Yashashree, 26, Nirmal Bag Society,  
Near Muktangnan English School, Parvati, Pune 411009  
Phone: 09890444795 Email: [enrichcons@gmail.com](mailto:enrichcons@gmail.com)

**MAHARASHTRA ENERGY DEVELOPMENT AGENCY**

An ISO 9001 : 2000 Reg. no. : RQ 91 / 2462



**Maharashtra Energy Development Agency**

(Government of Maharashtra Institution)

Aundh Road, Opposite Spicer College Road, Near Commissionerate of Animal Husbandary,  
Aundh, Pune, Maharashtra 411067

Ph No: 020-35000450

Email: [eee@mahaurja.com](mailto:eee@mahaurja.com), Web: [www.mahaurja.com](http://www.mahaurja.com)

ECN/2021-22/CR-14/1577

22<sup>nd</sup> April, 2021

**CERTIFICATE OF REGISTRATION  
FOR CLASS 'A'**

We hereby certify that, the firm having following particulars is registered with **MAHARASHTRA ENERGY DEVELOPMENT AGENCY (MEDA)** under given category as "Energy Planner & Energy Auditor" in Maharashtra for Energy Conservation Programme of MEDA.

**Name and Address of the firm** : **M/s Enrich Consultants**  
Yashashree, Plot No. 26, Nirmal Bag Society,  
Near Muktangan English School, Parvati,  
Pune - 411009.

**Registration Category** : *Empanelled Consultant for Energy Conservation Programme for Class 'A'*

**Registration Number** : *MEDA/ECN/2021-22/Class A/EA-03*

- Energy Conservation Programme intends to identify areas where wasteful use of energy occurs and to evaluate the scope for Energy Conservation and take concrete steps to achieve the evaluated energy savings.
- MEDA reserves the right to visit at any time without giving prior information to verify quarterly activities performed by the firm and canceling the registration, if the information is found incorrect.
- This empanelment is valid till **21<sup>st</sup> April, 2023** from the date of registration, to carry out energy audits under the Energy Conservation Programme
- The Director General, MEDA reserves the right to cancel the registration at any time without assigning any reasons thereof.

General Manager (EC)

# Enrich Consultants

Yashashree, 26, Nirmal Bag Society,  
Near Muktangang English School, Parvati, Pune 411 009  
Tel: 09890444795 Email: [enrichcons@gmail.com](mailto:enrichcons@gmail.com)

Ref: EC/SCP/20-21/01

Date: 26/05/2021

## CERTIFICATE

This is to certify that we have conducted Energy Audit at Shree Santkrupa College of Pharmacy, Ghogaon in the Academic year 2020-21.

The College has adopted following Energy Efficient practices:

- Maximum usage of Day Lighting
- Usage of Energy Efficient LED Light Fitting

We appreciate the support of Management, involvement of faculty members and students in the process of making the Campus Energy Efficient.

**For Enrich Consultants,**



**A Y Mehendale,**  
Certified Energy Auditor  
EA-8192

## **INDEX**

<b>Sr. No</b>	<b>Particulars</b>	<b>Page No</b>
I	Acknowledgement	5
II	Executive Summary	6
III	Abbreviations	7
1	Introduction	8
2	Study of Connected Load	9
3	Study of Present Energy Consumption	11
4	Carbon Foot Printing	13
5	Study of Usage of Alternate Energy	14
6	Study of LED Lighting	15

## **ACKNOWLEDGEMENT**

We Enrich Consultants, Pune, express our sincere gratitude to the management of Shree Santkrupa College of Pharmacy, Ghogaon for awarding us the assignment of Energy Audit of their Campus for the Academic Year: 20-21.

We are thankful to all the Principal and Staff members for helping us during the field study.

## EXECUTIVE SUMMARY

1. **Shree Santkrupa College of Pharmacy, Ghogaon** consumes Energy in the form of **Electrical Energy** used for various Electrical Equipment, Office & other facilities.

### 2. Present Energy Consumption & CO<sub>2</sub> Emission:

No	Parameter/ Value	Energy Purchased, kWh	CO <sub>2</sub> Emissions, MT
1	Total	7132	6.418
2	Maximum	1239	1.115
3	Minimum	377	0.339
4	Average	594.33	0.534

### 3. Energy Conservation projects already installed:

- Maximum Usage of Day Lighting
- Usage of Energy Efficient LED fittings

### 4. Usage of Alternate Energy:

- As on today College has not installed solar rooftop power plant. It is recommended to install solar power rooftop system on the college building as per availability of funds.

### 5. Usage of LED Lighting:

- The Total Lighting load of College is **8.62 kW**.
- The LED Lighting Load is **0.38 kW**.
- The % of LED Lighting to Total Lighting Load is **4.41 %**.

### 6. Assumptions:

1. **1 kWh** of Electrical Energy releases **0.9 Kg of CO<sub>2</sub>** into atmosphere
2. **100 LPD** Solar Thermal System saves **1500 kWh** of Electrical Energy per Annum.
3. Daily working hours-**4 Nos** (For Lighting Calculations)
4. Annual working Days-**120 Nos** (For Lighting Calculations)

### 7. References:

- For CO<sub>2</sub> Emissions: [www.tatapower.com](http://www.tatapower.com)

## **ABBREVIATIONS**

LED	:	Light Emitting Diode
MSEDCL	:	Maharashtra State Electricity Distribution Company Limited
IQAC	:	Internal Quality Assurance Cell
BEE	:	Bureau of Energy Efficiency
FTL	:	Fluorescent Tube Light
Kg	:	Kilo Gram
kWh	:	kilo-Watt Hour
CO <sub>2</sub>	:	Carbon Di Oxide
MT	:	Metric Ton

## **CHAPTER-I INTRODUCTION**

### **1.1 Objectives:**

1. To study present Energy Consumption
2. To Study the present CO<sub>2</sub> Emissions
3. To study usage of Alternate Energy
4. To study usage of LED Lighting

### **1.2 Table No 1: General Details of the College:**

<b>No</b>	<b>Head</b>	<b>Particulars</b>
1	Name of Institution	Shree Santkrupa College of Pharmacy, Ghogaon
2	Address	Ghogaon (Shivajinagar) Dist. Satara (M.H.) – 415 111
3	Affiliation	Shivaji University, Kolhapur




## CHAPTER-II STUDY OF CONNECTED LOAD

The major contributors to the connected load of the College include:

**Table No 2: Study of Equipment wise Connected Load:**

No	Equipment	Qty	Load, W/Unit	Load, kW
1	20 W LED	19	20	0.38
2	40 W FTL	206	40	8.24
3	Ceiling Fan	86	65	5.59
4	PC	65	150	9.75
5	Printer	7	150	1.05
6	Water Pump	1	3730	3.73
7	Other Equipment	100	150	15
<b>8</b>	<b>Total</b>			<b>44</b>

**Chart No 1: Study of Connected Load:**



## CHAPTER-III


### STUDY OF PRESENT ENERGY CONSUMPTION

In this chapter, we present the analysis of Electrical Energy Consumption.

**Table No 3: Electrical Bill Analysis- 2020-21:**

No	Month	Energy Purchased, kWh
1	Apr-20	1239
2	May-20	377
3	Jun-20	424
4	Jul-20	460
5	Aug-20	474
6	Sep-20	576
7	Oct-20	480
8	Nov-20	478
9	Dec-20	457
10	Jan-21	642
11	Feb-21	716
12	Mar-21	809
13	Total	7132
14	Maximum	1239
15	Minimum	377
16	Average	594.33

**Chart No 2: Variation in Monthly Energy Consumption:**



**Table No4: Variation in Important Parameters:**

No	Parameter/ Variation	Energy Purchased, kWh
1	Total	7132
2	Maximum	1239
3	Minimum	377
4	Average	594.33

## **CHAPTER-IV CARBON FOOTPRINTING**

**A Carbon Foot print** is defined as the Total Greenhouse Gas emissions, emitted due to various activities.

In this we compute the emissions of Carbon-Di-Oxide, by taking into account the usage of the Electrical Energy.

### **Basis for computation of CO<sub>2</sub> Emissions:**


- **1 kWh** of Electrical Energy releases **0.9 Kg of CO<sub>2</sub>** into atmosphere

Based on the above Data we compute the CO<sub>2</sub> emissions which are being released in to the atmosphere by the College due to its Day to Day operations

**Table No5: Month wise CO<sub>2</sub> Emissions:**

<b>No</b>	<b>Month</b>	<b>Energy Purchased, kWh</b>	<b>CO<sub>2</sub> Emissions, MT</b>
1	Apr-20	1239	1.115
2	May-20	377	0.339
3	Jun-20	424	0.381
4	Jul-20	460	0.414
5	Aug-20	474	0.426
6	Sep-20	576	0.518
7	Oct-20	480	0.432
8	Nov-20	478	0.430
9	Dec-20	457	0.411
10	Jan-21	642	0.577
11	Feb-21	716	0.644
12	Mar-21	809	0.728
13	Total	7132	6.418
14	Maximum	1239	1.115
15	Minimum	377	0.339
16	Average	594.333	0.534

**Chart No 3: Month wise CO<sub>2</sub>Emissions:**



**Table No 6: Important Parameters:**

No	Parameter/ Variation	Energy Purchased, kWh	CO2 Emissions, MT
1	Total	7132	6.418
2	Maximum	1239	1.115
3	Minimum	377	0.339
4	Average	594.333	0.534

## **CHAPTER V STUDY OF USAGE OF ALTERNATE ENERGY**

As on today College has not install solar roof-top PV plant, Solar thermal water heating plant; the percentages of uses of alternate energy to the annual energy demand work to be zero percent.

## CHAPTER VI STUDY OF USAGE OF LED LIGHTING

In this chapter, we compute the percentage of usage of LED Lighting to Annual Lighting power requirement.

**Table No 8: Percentage of Usage of LED Lighting to Annual Lighting Load:**

No	Particulars	Value	Unit
1	No of 40 W FTL Fittings	206	Nos
2	Demand of 40 W FTL Fitting	40	W/Unit
3	Total Electrical Load of 40 W FTL Fittings	<b>8.24</b>	kW
4	No of 20 W LED Tube Lights	19	Nos
5	Demand of 20 W LED Tube Light	20	W/Unit
6	Total Electrical Load of 20 W LED Fittings	<b>0.38</b>	kW
7	Annual Total Lighting Load = 3+6	<b>8.62</b>	kWh
8	Annual LED Lighting Load = 6	<b>0.38</b>	kWh
9	<b>Annual Lighting Requirement met by LED= <math>8*100/7</math></b>	<b>4.41</b>	%

